



NOTES:

1. ALL PIPE MUST BE TYPE 'K' COPPER OR NO LEAD BRASS ONLY. PVC NOT PERMITTED.
2. INSPECTIONS ARE REQUIRED FOR SYSTEM TIE-IN CONNECTION, ASSEMBLY CONNECTION, AND BACKFLOW CERTIFICATION.
3. A REDUCED PRESSURE DETECTOR BACKFLOW ASSEMBLY SHALL BE USED WHEN HIGH HAZARDS, AS DEFINED BY AWWA M-14 (E.G., RISK OF CHEMICAL ADDITION, MEDICAL FACILITIES, INDUSTRIAL FACILITIES, PROPERTIES USING RECLAIMED WATER, ETC.), EXIST.
4. FOR PRODUCTS AND MATERIALS SEE THE PROJECT SPECIFICATIONS AND THE CITY OF CAPE CORAL QUALIFIED PRODUCTS LIST.
5. PRIOR TO INSTALLATION, LOCATION OF BACKFLOW ASSEMBLY TO BE VERIFIED BY CITY OF CAPE CORAL.

W-240

3/4" TO 2" REDUCED PRESSURE BACKFLOW ASSEMBLY
(MULTI-FAMILY/COMMERCIAL)

NOT TO SCALE

REVISION DATE	
07-14-2022	
ADOPTION DATE	
08-17-2022	



CITY OF CAPE CORAL
UTILITIES DEPARTMENT
P.O. BOX 150027
CAPE CORAL, FLORIDA 33915-0027

DETAIL NAME	
3/4" TO 2" REDUCED PRESSURE BACKFLOW ASSEMBLY (MULTI-FAMILY/COMMERCIAL)	

DETAIL NO.
W-240